

## ADDENDUM NO. 1

**01. Project name of the Bidding Document:** Supply, Installation, Commissioning, and Maintenance of Pre-Fabricated Package Type Sewerage Treatment Plant for the Girls' Hostel at South Eastern University of Sri Lanka - Oluvil.

**02. Bid Reference Number:** SEU/SS/NCB/2025/02

**03. Date:** 03.09.2025

This Addendum is issued in response to the Pre-Bid Meeting held on 02.09.2025. This Addendum forms part of the Bidding Documents and modifies the original Bidding Documents issued for the project mentioned above.

### 04. Amendments to the Bidding Documents

#### Section IV: Price Schedule

**a).** To amend the following of the Cutter Pumps in the **Price Schedule** (ref. item no 1.02 of the Price Schedule on page 52 of the bidding document):

As per the original document (existing)	Change
<p>Supply and installation of Two Cutter pumps (80 mm) (<b>Flow Rate:</b> Up to 800 l/min, and <b>Head:</b> 13 meters) per location for</p> <ul style="list-style-type: none"><li>• 3 separate Septic tanks at Girls' Hostel with a Standby pump arrangement and</li><li>• Collection pit</li></ul> <p>The rate shall include <b>Supply &amp; Installation</b> of:</p> <ul style="list-style-type: none"><li>• <b>Two cutter pumps</b> per location for a standby operation setup</li><li>• <b>Electrical panel board</b> with automatic switching mechanism</li><li>• <b>Floater sensor switches</b> for level control</li><li>• <b>Power panel</b> with necessary circuit protection (MCB/MCCB, contactors, etc.)</li><li>• <b>Necessary structural works</b> (pump base, guide rails, etc.)</li><li>• <b>Testing &amp; Commissioning</b></li><li>• <b>Warranty &amp; Maintenance Support</b></li></ul>	<p>Supply and installation of Two Cutter pumps (80 mm) (<b>Flow Rate:</b> Up to 800 l/min, and the pump head may vary as per design calculations) per location for</p> <ul style="list-style-type: none"><li>• 3 separate Septic tanks at Girls' Hostel with a Standby pump arrangement and</li><li>• Collection pit</li></ul> <p>The rate shall include <b>Supply &amp; Installation</b> of:</p> <ul style="list-style-type: none"><li>• <b>Two cutter pumps</b> per location for a standby operation setup</li><li>• <b>Electrical panel board</b> with automatic switching mechanism</li><li>• <b>Floater sensor switches</b> for level control</li><li>• <b>Power panel</b> with necessary circuit protection (MCB/MCCB, contactors, etc.)</li><li>• <b>Necessary structural works</b> (pump base, guide rails, etc.)</li><li>• <b>Testing &amp; Commissioning</b></li><li>• <b>Warranty &amp; Maintenance Support</b></li></ul>

b). To include the below-mentioned item in the **Price Schedule** (new item).

Item No:	Description	Unit	Qty
1.09	Interconnection of the power supply for the pump control units. (The quoted rates shall include excavation, underground pipe and cable laying, installation of safety indicators, completion, testing, and commissioning.)	Item	01

#### 05. Additional Documents Provided

The following documents have been added as part of the bidding documents:

- Updated Price Schedule – Annex I

**All bidders are requested to acknowledge the receipt of this Addendum.**

  
Deputy Bursar  
Stores and Supplies Division

Deputy Bursar  
Stores and Supplies Division  
South Eastern University of Sri Lanka  
University Park, Oluvil # 32360